

# Case Study United Airlines Training Center

United Airlines Training and Data Center, 1200

E Algonquin Rd Des Plaines, IL 60016

## Report

Project Name	United Airlines Training and Data Center
Project Address	1200 E Algonquin Rd Des Plaines, IL 60016
Prepared By	William Lyons bill.lyons@elevateenergy.org



**ELEVATE ENERGY**  
Smarter energy use for all


## System Metrics

Design	Case Study United Airlines Training Center
Module DC Nameplate	1.41 MW
Inverter AC Nameplate	1.19 MW Load Ratio: 1.19
Annual Production	1,789 GWh
Performance Ratio	83.1%
kWh/kWp	1,267.2
Weather Dataset	TMY, CHICAGO OHARE INTL AP, NSRDB (tmy3, I)
Simulator Version	1413139342-a8a534a3c4-b277d3903c-854342d3fd


## Project Location



## Monthly Production



## Sources of System Loss



## Annual Production

	Description	Output	% Delta
Irradiance (kWh/m <sup>2</sup> )	Annual Global Horizontal Irradiance	1,406.6	
	POA Irradiance	1,524.3	8.4%
	Shaded Irradiance	1,482.5	-2.7%
	Irradiance after Reflection	1,432.7	-3.4%
	Irradiance after Soiling	1,404.1	-2.0%
	<b>Total Collector Irradiance</b>	<b>1,404.1</b>	<b>0.0%</b>
Energy (kWh)	Nameplate	1,981,859.7	
	Output at Irradiance Levels	1,957,777.5	-1.2%
	Output at Cell Temperature Derate	1,921,291.4	-1.9%
	Output After Mismatch	1,860,344.3	-3.2%
	Optimal DC Output	1,852,258.0	-0.4%
	Constrained DC Output	1,851,241.0	-0.1%
	Inverter Output	1,814,200.0	-2.0%
<b>Energy to Grid</b>	<b>1,789,410.0</b>	<b>-1.4%</b>	
Temperature Metrics			
	Avg. Operating Ambient Temp		13.1 °C
	Avg. Operating Cell Temp		19.8 °C
Simulation Metrics			
	Operating Hours	4696	
	Solved Hours	4696	

Condition Set													
Description	Condition Set 1												
Weather Dataset	TMY, CHICAGO OHARE INTL AP, NSRDB (tmy3, I)												
Solar Angle Location	Meteo Lat/Lng												
Transposition Model	Perez Model												
Temperature Model	Sandia Model												
Temperature Model Parameters	Rack Type	a		b		Temperature Delta							
	Fixed Tilt	-3.56	-0.075	3°C									
	Flush Mount	-2.81	-0.0455	0°C									
Soiling (%)	J	F	M	A	M	J	J	A	S	O	N	D	
	2	2	2	2	2	2	2	2	2	2	2	2	
Irradiation Variance	5%												
Cell Temperature Spread	4° C												
Module Binning Range	-2.5% to 2.5%												
AC System Derate	2.00%												
Module Characterizations	Module		Characterization										
	CS6U - 325P (Canadian Solar Inc.)		CS6U-325P-AG_MIX_CSI_EXT_V6_52_1500V_2016Q4.PAN, PAN										
Component Characterizations	Device			Characterization									
	PVI 60TL (Solectria)			Spec Sheet									
	PVI 50TL (Solectria)			Spec Sheet									

Components		
Component	Name	Count
Inverters	PVI 60TL (Solectria)	19 (1.14 MW)
Inverters	PVI 50TL (Solectria)	1 (50.0 kW)
AC Panels	1 input AC Panel	1
AC Panels	5 input AC Panel	1
AC Panels	7 input AC Panel	2
AC Home Runs	10 AWG (Copper)	14 (3,593.8 ft)
AC Home Runs	500 MCM (Copper)	4 (237.1 ft)
AC Home Runs	8 AWG (Copper)	1 (68.7 ft)
AC Home Runs	1 AWG (Copper)	5 (2,154.6 ft)
Home Runs	2 AWG (Copper)	9 (870.5 ft)
Home Runs	500 MCM (Copper)	5 (1,541.5 ft)
Home Runs	2/0 AWG (Copper)	28 (11,263.1 ft)
Home Runs	3 AWG (Copper)	28 (103.8 ft)
Combiners	1 input Combiner	35
Combiners	4 input Combiner	14
Combiners	5 input Combiner	2
Combiners	9 input Combiner	14
Combiners	12 input Combiner	5
Strings	10 AWG (Copper)	252 (42,727.0 ft)
Modules	Canadian Solar Inc., CS6U - 325P (325W)	4,345 (1.41 MW)

Wiring Zones			
Description	Combiner Poles	String Size	Stringing Strategy
North Building	12	17-18	Along Racking
SE Building	12	17-18	Along Racking
SC Building	12	17-18	Along Racking

Field Segments									
Description	Racking	Orientation	Tilt	Azimuth	Intrarow Spacing	Frame Size	Frames	Modules	Power
Field Segment 1	Fixed Tilt	Horizontal (Landscape)	10°	178.045°	1.3 ft	1x1	1,022	1,021	331.8 kW
Field Segment 2	Fixed Tilt	Horizontal (Landscape)	10°	178.431°	1.3 ft	1x1	175	175	56.9 kW
Field Segment 3	Fixed Tilt	Horizontal (Landscape)	17°	178.5°	1.3 ft	1x1	1,701	1,701	552.8 kW
Field Segment 4	Fixed Tilt	Horizontal (Landscape)	8°	178.5°	1.6 ft	1x1	1,449	1,449	470.9 kW

Detailed Layout





# Case Study United Airlines Training Center United Airlines Training and Data Center, 1200

E Algonquin Rd Des Plaines, IL 60016

## Shading Heatmap



## Shading by Field Segment


Description	Tilt	Azimuth	Modules	Nameplate	Shaded Irradiance	AC Energy	TOF <sup>2</sup>	Solar Access	TSRF <sup>2</sup>
Field Segment 1	10.0°	178.0°	1,021	331.8 kWp	1,487.1kWh/m <sup>2</sup>	421.6 MWh <sup>1</sup>	93.3%	98.5%	91.9%
Field Segment 2	10.0°	178.4°	175	56.9 kWp	1,488.9kWh/m <sup>2</sup>	72.3 MWh <sup>1</sup>	93.3%	98.6%	92.0%
Field Segment 3	17.0°	178.5°	1,701	552.8 kWp	1,478.8kWh/m <sup>2</sup>	699.7 MWh <sup>1</sup>	96.6%	94.6%	91.4%
Field Segment 4	8.0°	178.5°	1,449	470.9 kWp	1,482.7kWh/m <sup>2</sup>	595.8 MWh <sup>1</sup>	92.2%	99.4%	91.6%
<b>Totals, weighted by kWp</b>			<b>4,346</b>	<b>1.41 MWp</b>	<b>1,482.5kWh/m<sup>2</sup></b>	<b>1.79 GWh</b>	<b>94.2%</b>	<b>97.3%</b>	<b>91.6%</b>

<sup>1</sup> approximate, varies based on inverter performance  
<sup>2</sup> based on location Optimal POA Irradiance of 1,617.9kWh/m<sup>2</sup> at 34.3° tilt and 178.4° azimuth


## Solar Access by Month

Description	jan	feb	mar	apr	may	jun	jul	aug	sep	oct	nov	dec
Field Segment 1	96%	98%	99%	99%	99%	99%	99%	99%	99%	99%	97%	94%
Field Segment 2	96%	98%	99%	99%	99%	99%	99%	99%	99%	99%	98%	94%
Field Segment 3	81%	90%	97%	97%	98%	98%	97%	97%	98%	94%	85%	78%
Field Segment 4	99%	99%	99%	99%	100%	100%	99%	99%	100%	99%	99%	98%
<b>Solar Access, weighted by kWp</b>	<b>90.6%</b>	<b>95.3%</b>	<b>98.4%</b>	<b>98.5%</b>	<b>98.6%</b>	<b>98.6%</b>	<b>98.5%</b>	<b>98.5%</b>	<b>98.6%</b>	<b>97.0%</b>	<b>92.8%</b>	<b>88.6%</b>
<b>AC Power (kWh)</b>	<b>81,784.6</b>	<b>103,393.7</b>	<b>148,104.3</b>	<b>167,642.9</b>	<b>221,692.0</b>	<b>219,337.1</b>	<b>221,047.4</b>	<b>191,514.7</b>	<b>160,462.9</b>	<b>127,378.6</b>	<b>77,617.8</b>	<b>69,434.4</b>


### Monthly Production



### Sources of System Loss



### Southwestern Angle



### Southeastern Angle

